



BENGALURU MAHANAGARA PALIKE

Office of the Medical Officer of Health Mahadevapura Zone, Bangalore – 560048
NO: BBMP/MHO/MDP/PR/ 85 /2025-26 DATE:19/04/2025.

Annexure C PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Dr.Rakesh.N** Medical Officer of Health and **Akkamahadevi N., H.S.** (Name Of Officers with designation) from **BBMP Health Department**(Name of Officers with designation) inspected the **Ujval World School**, situated at K.No.1652, No.218,256/1, 256/2, 256/3, Municipal No.19, Kadugodi, Bangalore-560066.(Name & Address of the school) on 15-04-2025(date of inspection) and on the basis of Water Test Report (Attached) bearing no. 0001 of dated: 05-04-2025 (NABL ACCREDITED LABORATORY BANGALORE URBAN) certified that the **Ujval World School**, (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The Above NOC is Valid for the Period of One Year from the date of Issue.

Signature with Seal:

Name

: Dr.Rakesh.N

Designation

Medical Officer of Health
BBMP Mahadevapura Zone.

19/04/2025

To,

Ujval World School,
situated at K.No.1652,
No.218,256/1, 256/2, 256/3,
Municipal No.19,
Kadugodi, Bangalore-560066

Secretary

UJJVAL WORLD SCHOOL
Near Kadugodi Bus Stand,
Whitefield Post, Bangalore-560066.

Principal

UJJVAL WORLD SCHOOL
Near Kadugodi Bus Stand,
Whitefield Post, Bangalore-560066.



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.

NABL Accredited Laboratory Bangalore urban

TEST REPORT					
Address of the sampling location :- UJJVAL WORLD SCHOOL Near Kadugodi Bus Stand, Whitefield Post Bangalore-560066.				Report date: 05/04/2025	
				Report Number: 0001	
				Reference: TRF	
				Sample code: 0001	
				Date of Sample collection: 03/04/2025	
				Analysis start date: 04/04/2025	
				Analysis completion date: 04/04/2025	
Sample quantity: 1 Liter					
Sample Particulars: R.O water					
Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	6.9	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu S/cm$ @25°C Temp	100	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	<1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	60	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as $CaCO_3$, mg/l	16.6	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as $CaCO_3$, mg/l	16.0	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	3.2	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	2.0	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	7.5	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO_4 , mg/l	9.2	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	Nil	1	1.5	APHA 24 th Edition
14	Nitrate as NO_3 , mg/l	4.5	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: Megha K.S Senior Analyst/Junior Analyst			Authorized Signatory: Pavithra B.S Technical Manager: Pavithra B.S		



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---

Page 1 of 1

Principal
UJJVAL WORLD SCHOOL
 Near Kadugodi Bus Stand,
 Whitefield Post, Bangalore-560066.

Secretary
UJJVAL WORLD SCHOOL
 Near Kadugodi Bus Stand,
 Whitefield Post, Bangalore-560066.